

| No.         | Guide Sheet Name       | Guide Sheet Items   | Pass/<br>No Pass/Na |
|-------------|------------------------|---|---------------------|
| <b>RE10</b> | <b>TEMPORARY POWER</b> | Only allowed during construction , emergency tests or periods not exceeding 90 days CEC 590.3 (B)   | <b>INFORMATION</b>  |
|             |                        | Branch circuits shall originate in approved panel CEC 590 .4  |                     |
|             |                        | All receptacles shall be grounding type unless installed in metal raceway that qualifies as equipment grounding conductor CEC 590.4(D)  |                     |
|             |                        | All branch circuits shall include a separate equipment grounding conductor, and all receptacles shall be connected to the equipment grounding conductor CEC 590.4(D)  |                     |
|             |                        | No receptacles allowed on temporary lighting circuits CEC 590.4(D)  |                     |
|             |                        | Receptacles shall not be connected to the same ungrounded conductor of multiwire circuits that supply temp lighting CEC 590.4 9(D)  |                     |
|             |                        | Suitable disconnecting switches or plug connectors shall be installed to permit the disconnection of each temporary circuit. Multiwire branch circuits shall be provided with means to disconnect simultaneously all ungrounded conductors at the panel board |                     |
|             |                        | Decorative lighting used for holiday lighting and similar purposes, in accordance with CEC 590.3 (B)  |                     |
|             |                        | 125 volt, single phase 15-20 and 30 amp outlets that are not part of permanent building wiring shall be GFCI protected 590.6 (A)  |                     |
|             |                        | All portable toilets with service wiring shall be staked to the ground (soil)<br>OAK  |                     |
|             |                        | For wiring over 600 volts suitable fencing or other effective means shall be provided to limit access to authorized and qualified personnel CEC 590.7   |                     |